




Severe Accident Assessment of NRU Reactor



*R. Leung and C. Blahnik
Ninth International Probabilistic
Safety Assessment and
Management Conference
May 2008, Hong Kong, China*


 **AECL EACL**

UNRESTRICTED





Introduction

- **National Research Universal (NRU) reactor**
 - heterogeneous reactor in operation since 1957
 - power up to 135 MW thermal
 - cooled and moderated by D₂O
 - 227 vertical lattice sites arranged in hexagonal array
 - control and fuel rods in ~ 1/2 sites
 - remaining sites for experiments and isotope irradiations
 - three reactor test sections supplied from two separate high-pressure, high-temperature loops
 - two independent trip systems that activate shutdown system





Introduction (continued)





Introduction (continued)

- **Severe Accident Assessment (SAA) performed to extend internal event analyses of upgraded NRU facility into severe accident realm**
- **Regulatory bodies or IAEA do not define risk goals for non-power reactors**

Acceptance criteria defined for
and applied in NRU SAA

Criterion	Acronym	Value (a ⁻¹)	Explanatory Notes
Severe Core Damage Frequency	SCDF	1·10 ⁻⁴	Risk surrogate. Consensus value for existing older nuclear power plants, used in past CANDU PSAs.
Large Release Frequency	LRF	1·10 ⁻⁶	Risk surrogate. Large release is 10 ¹⁵ Bq of Cs-137. Proposed for new nuclear power plants in Canada (subsequently reduced to 10 ¹⁴ Bq).
Individual Early Fatality Risk	IEFR	4·10 ⁻⁶	Value is 1% of the risk of prompt death from all other accidents in Canada; similar to value used in past CANDU PSAs.
Individual Delayed Fatality Risk	IDFR	4·10 ⁻⁵	Value is 1% of the risk of delayed fatalities from all types of cancer in Canada; similar to value used in past CANDU PSAs.
Large Release Risk	LRR	7·10 ⁻⁴	Addresses the same issue as the surrogate LRF (risk that large numbers of nearby residents would have to be relocated).




Level 1 PSA Insights

- **Reactor Damage States (RDS) are derived from Level 1 event tree and fault tree analyses using feedbacks from Level 2 deterministic analyses**

fuel release $\leq 1\%$

State	Description	Frequency Magnitude	
SR	Stable fuel state – limited cladding damage.	E-02/year	
RDS4	Local fuel damage due to a power cooling mismatch in an experimental loop	E-03/year	
RDS3	Local fuel damage due to a power cooling mismatch in a single flow tube	E-03/year	
RDS2	Widespread fuel damage due to a power cooling mismatch at decay power	RDS2A without confinement bypass	E-05/year
		RDS2B with confinement bypass	E-05/year
RDS1	Widespread fuel damage due to a power cooling mismatch at high power	E-07/year	
RDS0	Widespread fuel damage due to a failure to shut down after a power excursion	E-08/year	

SCDF criterion is met





Level 2 PSA Insights

Deterministic Assessments

NRU reactor employs low enriched uranium (LEU) fuel cycle based on U_3Si dispersed in Al

- Aluminium fuels liquefy at low temperatures ($\sim 660^\circ C$)
- U_3Si exothermically reacts with aluminium at $\geq 500^\circ C$
 - reaction heat is small relative to decay heat \rightarrow small shift in timing of events
- Molten fuel releases only few fission products (noble gases, iodine and cesium) unless significantly superheated
- Interactions of molten fuel with steam or water do not produce appreciable hydrogen and do not readily trigger steam explosions unless melt is superheated to $\geq 1000^\circ C$
 - solid silicide and aluminide particles suspended in liquid aluminium tend to inhibit fragmentation of melt that is necessary for steam explosion




Level 2 PSA Insights (continued)

Deterministic Assessments

Liquefied fuel is mobile

- Melt flows (relocates) into contact with various passive heat sinks and solidifies
 - conduction heat transfer is important
- Melt superheating during relocation is only possible in fast and large power excursions
 - catastrophic steam explosions are not plausible during core meltdown at steady or decay power levels




Example of relocation at decay power slowly voiding vessel



Level 2 PSA Insights (continued)

Deterministic Assessments

Key passive heat sink in intact reactor vessel is residual water inventory



- Available for > 1 day after onset of Severe Core Damage (SCD)
- Residual water does not prevent fuel melting and relocation within vessel but precludes debris from re-heating and re-melting on vessel bottom

intermittent releases of melt into vessel



Level 2 PSA Insights (continued)



Deterministic Assessments

Active or passive heat sinks come into play in voided reactor vessel

available

active Thermal Shield Cooling

unavailable





Level 2 PSA Insights (continued)


Deterministic Assessments

Reconfigured Reactor Core

- Broad range of debris/moderator geometries = potential for re-criticality
- All conceivable configurations evaluated by supplementary analysis

Configuration most prone to re-criticality in NRU is array of debris cylinders submerged in D₂O

Subcritical even with neutron absorbers (control rods) assumed not to be present in reconfigured core







Level 2 PSA Insights (continued)

Deterministic Assessments

no retention in transport
credited for confinement bypass



retention during transport evaluated

Release of Fission Products

- Volatile fission products are released from molten core continuously
- Gases and vapours remain largely confined within breached reactor vessel until accident termination
 - Operator actions to quench debris purge volatile fission products from vessel

← All potential release routes from reactor vessel into environment are identified and categorized



Level 2 PSA Insights (continued)

Probabilistic Assessments

- **Destructive severe accident phenomena are plausible in SCD accidents due to fast and large power excursions**
 - steam explosion and hydrogen deflagration
 - power excursions have very low frequency of occurrence in NRU
- **Modest water coolant interactions capable of reactor vessel damage are possible in other SCD sequences but are not imminent**
 - pressure surges in vessel → consequential draining of vessel
- **There are no other challenges to integrity of reactor vessel or confinement for at least one day after SCD onset**

NRU Accident Progression Event Trees (APETs) are relatively simple. Branches deal mainly with unavailability of confinement subsystems.



Level 2 PSA Insights (continued)

Probabilistic Assessments

Release Source Terms (RSTs)


Magnitude & Composition (% core inventory)				Duration (hr)	Location	Frequency Magnitude (per year)
Noble Gases	Cesium & Iodine	Tellurium	Other			
100	100	100	100	1	building	E-08
100	100	10	0	1	building	E-07
100	10	1	0	24	building	E-08
100	10	1	0	24	stack	E-08
100	1	0.1	0	24	building	E-05
100	1	0.1	0	24	stack	E-05

- **RSTs are stylized categories**
 - pre-defined on basis of fission product volatility before deterministic transport assessments were performed
 - transport analyses show that, for the last four RST categories in above table, fractional release of cesium is exaggerated by ~ factor of ten



Level 3 PSA Insights

- **Individual Early Fatality Risk is of the order of 10^{-8} per year**
- **Individual Delayed Fatality Risk is of the order of 10^{-7} per year**
 - With these values, Large Release Risk need not be enumerated → LRR criterion is met when IDFR criterion is met





Conclusions

- **SAA provides information on severe accidents**
 - previously missing in NRU safety assessments
- **Acceptance criteria met with large margin to spare**
 - Uncertainties are being addressed by supplementary assessments and experiments
 - It is evident that operation of upgraded NRU reactor does not present public with any additional risks that are significant in comparison with risks to which public is normally exposed
- **Insights applied in Severe Accident Management, emergency planning and risk-informed decision-making**






Level 2 PSA Insights (continued)

Deterministic Assessments

Active or passive heat sinks in voided reactor vessel





Level 2 PSA Insights (continued)

Deterministic Assessments

Debris re-criticality is very low probability phenomenon in NRU reactor

