



Data analysis of the reactor pressure, coolant level and main recirculation flow calibration data and failure events for Olkiluoto 1 and Olkiluoto 2

PSAM9 Conference
Hong Kong, May 19-23, 2008

Contents

- **TVO in a nutshell**
- **Introduction**
- **Analysis content**
 - Analysis of calibration data
 - Analysis of failure events
 - PRA evaluation
- **Results and conclusions**

Teollisuuden Voima Oy (TVO)

Company

- Privately owned power company in Finland
- Established in 1969
- Personnel about 700
- Annual turnover about million 230 M€
- Sells electricity only to the shareholders at cost basis



Existing NPP Units (Olkiluoto 1 and Olkiluoto 2)

- 2 x 860 MW, BWR, Westinghouse Atom
- Commercial operation 1979 and 1982
- Modernization and upgrade in 1994-1998 and 2005-2006




New NPP Unit (Olkiluoto 3)

- 1 x 1,600 MW, PWR, Framatome-Siemens consortium
- Commercial operation in 2011

Coal Condensing Power Plant Unit (Meri-Pori)

- 257 MW stake in 565 MW coal condensing unit



Subsidiaries


- Posiva Oy (60%), responsible for the final disposal of spent fuel
- TVO Nuclear Services Oy (100 %), specialized in know-how consulting

Introduction

- **Surveillance test evaluation**
 - Internal project – started 2001
 - Tests included in Technical Specifications
 - Limited to tests that are performed during annual outages
 - Risk informed approach
- **Main goals**
 - Possibilities to reduce the effort put on testing activities
 - To study the possible improvement of test procedures
 - Risk reduction possibilities e.g. with alternative test arrangements
- **Organizations involved**
 - Nuclear Safety, Operational Safety, Operation and Maintenance
 - comprehensive aspects from safety, operation and maintenance were gained in the decision-making process


Introduction continues...

- Case study – calibrations of reactor measurements
 - reactor pressure, coolant level and main recirculation flow
 - 211K101- K104, 211K111 - K114
 - 211K401- K404, 211K411 - K414
 - 211K301- K304, 211K311 - K314
 - Calibration interval extension?
 - Sequential versus staggered testing?
- OL1/OL2 Operating experience, historical data
 - Analysis of calibration data
 - Analysis of failure reports
 - Analysis of IE's (PRA)
- OL1/OL2 PSA model
 - Determination of risk significance of calibrations




Analysis of the calibration data



- **Source:**
 - Plant specific database for calibration data (EERO)
 - Contains information of all components included in a measurement chain
 - Calibration measurement data
 - Calibration points within measurement range
 - » e.g. fine pressure 60...80 bar, fine level +2,5...+6,4 m
 - Calibration is performed once per year in connection of annual outage
- **Time period:**
 - Calibration data from years 1982-2000



Example of pressure measurement



Analysis of the calibration data, cont.



Equipment	Action limit
transmitter (level, pressure, flow, temperature)	$\pm 0,08$ mA
isolation amplifier	± 50 mV
electronic-limit switch	± 30 mV
IU-converter	± 50 mV
summing amplifier	± 50 mV
majority switch	± 50 mV

Analysis of the calibration data, cont.

OL2, Pressure measurement Calibrations (1986-2000)	Frequency of exceeding the action limit (1/year)
Transmitters (F)	0,48
Transmitters (C)	0,03
Transmitters (F&C)	0,26
IU conv., QAIC	0,007
UU conv., QAGO	0,002
Electronic limit switch (F)	0,035
Electronic limit switch (C)	0,029

Analysis of failure events

- **Plant specific maintenance database as source**
 - **“TTJ” (former ATV)**
 - Analysis of failure events reported
 - Covers time period 1983-2001
 - Critical failures and their failure modes in measurement chains
 - **Simplified approach was applied**
 - **criticality classification**
 - critical, repair critical, non critical
 - **failure mode for critical failures**
 - according to coding and description in the failure report
 - e.g. “spurious output” or “no output”

Analysis of failure reports, cont.

Failure reports 83-01

Reactor Pressure

OL1	tot	Cri	Rcri	N
211K101-K104	2			2
211K111-K114	4		1	3
Total OL1	6	0	1	5

OL2	tot	Cri	Rcri	N
211K101-K104	4		3	1
211K111-K114	2			2
Total OL2	6	0	3	3

Fine pressure OL1/OL2	6	0	3	3
Coarse Pressure OL1/OL2	6	0	1	5

Total OL1/OL2	12	0	4	8
----------------------	-----------	----------	----------	----------

12 failures are reported

- **no critical failures**

Reactor level

OL1	tot	Cri	Rcri	N
211K401-K404	8	1	3	4
211K411-K414	8	1	3	4
Total OL1	16	2	6	8

OL2	tot	Cri	Rcri	N
211K401-K404	10	4	3	3
211K411-K414	16	4	9	3
Total OL2	26	8	12	6

Fine Level OL1/OL2 yht.	18	5	6	7
Coarse Level OL1/OL2 yht.	24	5	12	7

Total OL1/OL2	42	10	18	14
----------------------	-----------	-----------	-----------	-----------

42 failure reported - 10 critical failures

- **7 cases – no output**
 - transmitter failures
- **1 human error**
 - maintenance and restoration of measurement channel
- **2 spurious**
 - inadvertent trip of one channel

Analysis with OL1/OL2 PRA model

- **Modelling in OL1/OL2 PRA**

- Component boundary - components from transducer up to the electronic limit switch in each measurement channel

- **Reactor pressure**

- 211K101 – 211K104 – P/I low signal
 - 211K111 – 211K114 – P/I high signal

- **Reactor level**

- 211K401 – 211K404 – DP/I high signal
 - 211K411 – 211K413 – DP/I high signal

- **Reactor flow**


- 211K301-K304, K311-K314 – not modelled (MC- flow signal)

- **Electronic limit switches – different actuation set-points**

- **Level - limit values H2, L2, L3, L4**

- **Pressure, limit values H4 and L3**


- Impulse lines & 516-logic is modelled, but not considered in this analysis



211 K101 - 104	H4	74 bar	SS6
	H3	73 bar	
	H2	72 bar	
	H1	71 bar	
	L0	70 bar	
	L1	69 bar	
211 K111 - 114	L2	66 bar	(TS)
	L24	51 bar	A22
	L3	12 bar	

Analysis with OL1/OL2 PRA model, cont.

- Initiating event for OL1/OL2 units (1983-2001)
 - No plant disturbance has been occurred due to reactor pressure, reactor level or reactor flow measurements
- In connection of RPS (516) system analysis in PRA
 - Multiple human errors related to calibration treated as “CCFs”
 - Significant contributor to CDF
- Modeling of multiple human error in X1/I2 calibration
 - Low level in reactor pressure vessel (X1:L3=2,0m / I2:L4=0,7m)
 - Most important “multiple human error” - probability is estimated to be rather low $2 \cdot 10^{-5}$
 - Already reduced some years ago after the test procedure changes



Analysis with OL1/OL2 PRA, cont.

- **PRA model (Rev. 334)**
 - **Reactor pressure and level measurement**
 - **contribution to the core damage frequency without considering system 516 and impulse lines in system 211**
 - $\sim 2,6 \cdot 10^{-6}$ 1/ra thus 13 % of total CDF ($\sim 2 \cdot 10^{-5}$ 1/year)
 - **The most important contributors**
 - **human errors, especially multiple errors in calibration (CCF)**
 - **Fussel-Vesely importance measure is 13%**
 - **Risk increase factor 650**
 - **most important – RPS conditions I2/X1 of reactor level measurement**

Results and conclusions

- In past sequential calibrations have been performed annually during the outages (four-fold trains A, B, C and D)
- Based on the study the calibration interval could be extended according to calibration data and failure data analysis with exception
 - Flow measurement
 - the calibration interval could be longer, but due to operational reasons the calibration is needed every outage after refueling – thus no change proposed
- According to PRA study the core damage risk can be reduced significantly
 - if the calibrations are staggered in train pairs
 - the threefold and quadruple calibration errors can be eliminated practically
 - ☞ trains A and C will be calibrated every second year and trains B and D correspondingly

Results and conclusions, cont.

- **Technical Specification change application was sent to STUK**
 - change in reactor and pressure level measurements
 - consisted on the proposal of staggering the calibration activity
- **STUK accepted this proposal at the end of the year 2005**
 - effective during the outages 2006

27.5.2003



4.10.2004



25.8.2005



1.3.2006



30.7.2007



May 2008



May 2008





May 2008

Thank you!

