

# Functional Safety in the Process Industry

27.03.2018




Ken Wong

Endress+Hauser (HK) Limited



## About the Speaker

---



### Ken Wong MK

Head of Marketing/ Level and Pressure Product Specialist

Endress+Hauser (HK) Limited

Tel.: +852 2528 3120 / Mobil: +852 6331 7772 / E-mail: [ken.wong@hk.endress.com](mailto:ken.wong@hk.endress.com)

<https://www.linkedin.com/in/ken-mk-wong-b733ba145/>

# Safety Instrumented Systems (SIS) in the Process Industry

---

- Definition of “Risk”
- Risk assessment and Risk reduction by SIS
- Safety Integrity Level (SIL)
- Design of Safety Instrumented Systems
- Safety Parameters and SIL determination
- Structure of Safety Instrumented Systems
- Functional Proof Testing
- Order Code and Documentation





# BP AMOCO Refinery Explosion Texas City March 2005

## Reason:

- safety systems ignored during maintenance process
- inappropriate design of safety systems
- uncontrolled release of fuel from a vent stack
- inappropriate behavior of workers trying to start and remove a truck
- control room with many workers located close to distillation column

## → Safety Culture!

## Consequence:


- 15 People KILLED
- 180 INJURED
- estimated costs  
US\$1,000,000,000




## What is “Risk” ?

---

- Risk = Probability (P) of Event Occurrence x Damage (D)
- Tolerable risk = maximum risk, which is acceptable according to moral concepts (German VDE 2180)
- Risk reduction:  
Reduction of initial risk below tolerable risk by organizational, constructional or protection measures (e.g. Safety Instr. Systems)
- Concept of Functional Safety:



# Risk Reduction by a Safety System



# IEC 61508 & IEC 61511: Functional Safety of Electrical/Electronic/Programmable Electronic Systems

**Manufacturer**



**User**



safety related system standards

**IEC 61508**

**7 parts**

**Manufacturers &  
suppliers of devices**


**IEC 61511**

**3 parts**

**Safety Instrumented  
Systems Designers,  
Integrators & Users**

**American Standard: ANSI/ISA 84.01**

# Overall Safety Life-Cycle acc. IEC 61511




Source: DIN EN 61511-1 Fig. 8





# Hazard and Risk Assessment of a Process

Risk graph:



Risk parameters:

W - Occurrence Probability

W1: very low probability  $< 0,03/\text{year}$

W2: low probability  $< 0,3 / \text{year}$

W3: relative high probability  $> 0,3/ \text{y}$

C- Extent of damage

C1: slight injury

C2: severe irreversible injury to one or more persons or death of a person

C3: Death of several persons

C4: Catastrophic consequences, multiple deaths

F- Exposure time

F1: seldom to relatively frequent


F2: frequent to continuous

P- Hazard Avoidance

P1: possible under certain conditions

P2: hardly possible

# Risk Reduction by Safety Instrumented Systems



# Operational modes of safety systems

High demand mode (HDM)  
or continuous mode  
demand of the safety function  
**more than once a year**

Safety function  
only active  
during demand



Safety function  
frequently or  
continuously active



Low demand mode (LDM)  
demand of the  
safety function  
**once a year or less**

E.g. machinery industry


E.g. process industry

## „Quantification“ of Risk and Protection Measures

Risk	SIL	Accepted frequency of a failure of the protection measure	Failure rate PFH	Failure probability PFD*
Low	SIL 1	< 1 dangerous fault in 10 years	$<10^{-5}$ 1/h	$<10^{-1}$
Mean	SIL 2	< 1 dangerous fault in 100 years	$<10^{-6}$ 1/h	$<10^{-2}$
High	SIL 3	< 1 dangerous fault in 1000 years	$<10^{-7}$ 1/h	$<10^{-3}$
Very high	SIL 4	< 1 dangerous fault in 10.000 years	$<10^{-8}$ 1/h	$<10^{-4}$


\* per demand, assuming 1 demand/year

## Reliability of Safety Instrumented Systems





# Functional Safety Management - Design Process



## Documentation



# TÜV Certified Functional Safety Management




# Safety Level of Safety Instrumented Systems

---

- Failure Mode and Effect Analysis (FMEA)
- Total Failure Probability (PFD, PFH)
- Architectural Constraints (SFF, HFT)

# Random Failures of Electronic Components




Note: Failure rate often specified in FIT = 1 Failure/ $10^9$  h =  $10^{-9}$  /h



# Failure Mode and Effect Analysis (FMEA)

Example:



Additionally: FMEA of mechanical Components (z. B. Sensor)



# Failure Mode Effect Analysis (FMEA)

- Pre-condition:
- determine safety path (e.g. 4...20 mA output)
  - determine accuracy under fault condition ( e.g.  $\pm 2 \%$ )

Failure modes:

- dangerous faults
- safe faults
- undetected faults
- detected faults

Probability of Failure Modes	Detected faults	Undetected faults
Safe faults	$\lambda_{sd}$	$\lambda_{su}$
Dangerous faults	$\lambda_{dd}$	$\lambda_{du}$

$$\lambda_{\text{tot}} = \lambda_{su} + \lambda_{sd} + \lambda_{du} + \lambda_{dd} (+\lambda_{\text{not relevant}})$$

$$\text{MTBF} = 1/\lambda_{\text{tot}}$$

PFD, PFH


# Failure Modes of Safety Function

$\lambda_{sd}$  = Safe detected Failure

**Example (cont. overfill protection):**

Short circuit of 4..20 mA-output

→ Current >20 mA indicates overfilling and “Alarm”



$\lambda_{su}$  = Safe undetected Failure

**Example (limit switch 8/16 mA):**

Failure leads to 8 mA output

→ Safety function activated (fault alarm!)



**PFH, PFD**


$\lambda_{dd}$  = Dangerous detected Failure

**Example:**

Ceramic cell broken in Deltabar

▪ Broken cell could result in a “valid” measured value but...

→ Internal “Diagnostic” in active sensor



$\lambda_{du}$  = Dangerous undetected fail.

**Example:**

Output „frozen“ between 4...20 mA independent of the process variable

→ no warning

Information not available




$$\lambda_{tot} = \lambda_{su} + \lambda_{sd} + \lambda_{du} + \lambda_{dd}$$

$$MTBF = 1 / \lambda_{tot}$$


## Probability of a failure on demand - PFD

Example: Safety component with low demand frequency ( $\sim 1/a$ )

$$\text{PFD} \approx \lambda_{du} \cdot t \quad (\lambda t \ll 1)$$



## Partial Proof Testing (PTC < 100%)




$$PFD_{av} \approx \frac{1}{2} \lambda_{du} \times Ti \times PTC + \frac{1}{2} \lambda_{du} \times LT \times (1-PTC)$$

PTC= Proof test coverage (1=100 %)

Ti = Test interval

LT= life time

# Partial Proof Testing + Full Proof Test



$$PFD_{av} \approx \frac{1}{2} \lambda_{du} \times T_i \times PTC + \frac{1}{2} \lambda_{du} \times T_j \times (1-PTC)$$

PTC= Proof Test Coverage (1=100 %)

$T_i$  = Test interval (<100 %)      $T_j$  = Test interval (100%)



# Constraints of the Hardware Architecture

- Device Type (Type)
- Safe Failure Fraction (SFF)
- Hardware-Failure Tolerance (HFT)

## Device Types

---

- Device Type A (simple devices)

All faults determined

e.g. analogue electronic devices




- Device Type B (complex devices)

Not all faults determined

e.g.  $\mu$ P-controlled electrical/electronic devices





## Safe Failure Fraction (SFF)





## Hardware-Failure Tolerance (HFT)


- $HFT = 0 \rightarrow$  no redundancy  
1 fault  $\rightarrow$  loss of safety function
- $HFT = 1 \rightarrow$  redundant architecture  
2 faults  $\rightarrow$  loss of safety function
- $HFT = 2 \rightarrow$  3 channel architecture  
3 faults  $\rightarrow$  loss of safety function



oder



oder



# How to determine architectural constraints?

Example: Device Type B, HFT = 0, SFF = 92% → SILmax ?

Safe Failure Fraction (SFF)	Hardware-Failure Tolerance (HFT) (Typ B – complex device)		
	0	1	2
< 60%	Not allowed	SIL 1	SIL 2
60% ... < 90%	SIL 1	SIL 2	SIL 3
90% ... < 99%	SIL 2	SIL 3	SIL 4
≥ 99%	SIL 3	SIL 4	SIL 4





# Basic Safety Parameters

Probability of Failure on Demand:  $PFD_{av} \approx 1/2 \lambda_{DU} \times T_p^*$

Safe Failure Fraction:  $SFF = \frac{\sum \lambda_{sd} + \sum \lambda_{su} + \sum \lambda_{dd}}{\sum \lambda_{tot}}$

Hardware Fault Tolerance:  $HFT = \text{No. of tol. Faults}$

Device Type:  $Type = A \text{ or } B$

\* 1 channel System



**Safety Integrity Level**  
**SIL 1...4**

# Design of Safety Instrumented Systems

- Single Channel System
- Multi-Channel System


# Single Channel System

Design rules

$$SIL_S, SIL_L, SIL_A \geq SIL_{\text{system}}$$

$$PFD_S + PFD_L + PFD_A < 10^{-SIL_{\text{system}}}$$

## Example: single channel overflow protection



	Sensor	Steuerung	Aktor	System
SIL	2	3	2	≤2
PFD <sub>av</sub>	0,3x10 <sup>-2</sup>	0,05x10 <sup>-2</sup>	0,4x10 <sup>-2</sup>	0,71 x 10 <sup>-2</sup>

➔ System  
= SIL 2


# Multichannel Architecture

---

- Homogeneous and diverse Redundancy
- Design rules

# Redundancy: Homogeneous or diverse?

## Homogeneous Redundancy (**same** instruments)



### Advantage of **homogeneous** system

- Control of random faults
- Simple stock management, commissioning, maintenance ...

**Note:** Systematic Integrity  
(e.g. Software) can not  
be enhanced!

## Diverse Redundancy (**different** instruments)




### Advantage of **diverse** system

- Control of random and systematic faults (device + process)
- systematic integrity can be enhanced




## MooN voting rules




Examples:

1oo2 voting




2oo3 voting




channel

# Design of Multi-Channel Systems


Safety



# Design Rules of Multi-channel Systems




## Subsystem Sensor



## Subsystem Logik



## Subsystem Actuator





# Proof-testing with Endress+Hauser Instruments

---

- The Liquiphant Family
- Level Continuous
- Pressure
- Flow Instruments and Fieldcheck
- Overview of test procedures and parameters

## Example 1- Level switch



Liquiphant M FTL 50/51

Liquiphant S FTL 70/71

Liquiphant S FDL 80/81/85 + FTL 825 Fail Safe



# The Liquiphant Family – SIL qualified

## SIL2 MIN/MAX



Liquiphant M FTL 50/51

Liquiphant S FTL 70/71

Electronic:

FEL51, 2-Wire AC


FEL52, 3-Wire DC-PNP

FEL54, AC/DC DPDT

FEL55, 8/16 mA

### Periodic proof testing

- Wet testing or
- Test in reference tank



PFM

FTL 325P

Liquiphant M FTL50/51

Liquiphant S FTL70/71

+ FEL 57+ FTL3x5 P

### Periodic proof testing

- Testgenerator (push-button)



NAMUR

FTL 325N

Liquiphant M FTL50/51

Liquiphant S FTL70/71

+FEL 56/58 + FTL325N

### Periodic proof testing

- Wet testing or
- Test in reference tank
- Alarm simulation (push-but)

## SIL3 MAX



Liquiphant M FTL50/51

Liquiphant S FTL70/71

+FEL 57 + FTL3x5 P

### Periodic proof testing

- Testgenerator (push-button)

FTL 325P


PFM

## SIL 3 MIN/MAX

FTL 80,81,85



FTL 825



Liquiphant S Failsafe FTL8x


Nivotester FTL825

### Periodic proof testing

- Continuous self-diagnostic
- Testgenerator (push-button)
- Proof test interval ≤ 12 years!


# Self Diagnostics Liquiphant M/S (FEL 51... 67)

- Continuous monitoring of vibration frequency
- Reliable alarm funktion with each electronic insert!




## New: Liquiphant Fail Safe FTL 80/81/85 + FTL 825

### SIL3 MIN/MAX



### Safety function

- SIL 3 capable with **single** device
- **min/max safety** function
- **2** safety relay outputs (FTL 825)
- proof test generator with **push-button**
- proof test interval  $\leq$  **12 years** !



# Total Proof test coverage (DC+PTC) according to IEC 61508



Total coverage (DC+PTC)	FTL80/81/85+ FTL825	FTL 80/81/85+ SSPS
Wet test	99% (Procedure IA MAX/MIN)	99% (Procedure IIA MAX/MIN)
Simulation (in situ testing!)	98 % (Procedure IB) (Testbutton: FEL85 od. FTL825)	95 % (Procedure IIB MAX/MIN) (Testbutton: FEL85)



## Example 2 – Level Continuous

Levelflex FMP 4x, FMP 5x


Micropilot M/S FMR xxx



## Levelflex FMP 5x

### Safety Function:

- **Level** of liquid or bulk solid material (4..20 mA)
- **Interface** between 2 liquids (4..20 mA)
- Min, max, range
- SIL 2 (1oo1), SIL 3 (1oo2)
- LDM, HDM



### Proof test procedures:

Test criterion: Trip level  $\pm 2\%$

- Wet testing in the application/reference tank (PTC $\approx 98\%$ , Ti= 3 years)
- In-situ level simulation (PTC $\approx 92\%$ , Ti= 1 year)  
(no process shutdown required!)



## Micropilot FMR 5x


### Safety Function:

- **Level** of liquid or bulk solid material (4..20 mA)
- Min, max, range
- SIL 2/3
- LDM, HDM

### Proof test procedures:


Test criterion: Trip level  $\pm 2\%$

- a) Wet testing in the application (PTC $\approx 98\%$ , Ti=2 years)
- b) Simulation (PTC $\approx 55\%$ , Ti=1 year)



# Proof testing with Level Radar

Independent High Level Alarms / Radar – Proof Testing external



Combined checker  
plate for  
functional proof  
testing

External Checker  
plate for  
functional proof  
testing

## Example 3 - Pressure Measurement

Cerabar S PMC 71, PMP 71/72/75

Deltabar S PMD 70/75, FMD 76/77/78



## Cerabar S, Deltabar S

---

### Safety function

- Pressure, Level (4... 20 mA)
- min, max, range
- SIL 2 (1oo1), SIL 3 (1oo2)
- LDM, HDM



### Proof test procedures:

- test with reference pressure ( $T_i \leq 5$  years,  $PTC \approx 99\%$ )
- in-situ test with signal simulation ( $T_i = 1$  year,  $PTC \approx 50\%$ )  
tool: HART communication or Display keyboards

Test criterion: trip level  $\pm 2\%$

## Example 4 – Flow Measurement

Promass 80, 83 [Coriolis ]

Promag 50, 53 [MID]

Prowirl 72, 73 [Vortex]





## Promass 80, 83 Promag 50, 53 Prowirl 72,73

---

### Safety function:

- Volume flow, Mass flow<sup>1</sup>, density<sup>1</sup> (4...20 mA) <sup>1</sup>Promass only!
- Min, max, range
- SIL 2 (1oo1), SIL 3 (1oo2) <sup>1</sup>

### Proof test procedures:

Test criterion: Trip level  $\pm 2\%$


1. in- or off-line test with a **calibration rig** (PTC $\approx 98\%$ , Ti  $\leq 5$  years)  
mobile or factory calibration: volume flow, mass flow or density
2. in- or off-line test with the **integrated totaliser** (PTC $\approx 98\%$ , Ti  $\leq 5$  years)  
measuring a reference volume or mass
3. in-line test of density by **reference liquids**<sup>1</sup> (PTC $\approx 98\%$ )
4. in-line test with the **Field Check** (PTC  $\approx 90\%$ , Ti = 1 year)  
(volume flow, mass flow, density)  
„**Field Care**“  $\rightarrow$  **automatised data recording**  
 $\rightarrow$  calibration rig/totalizer test:  $\leq 10$  years

## Flow Measurement - Easy proof testing

**Example: Promag 50, 53 , Promass 80, 83**


Proof-test methods, either

- Off-line proof test with **calibration rig**
- In-line proof test using the **totalizer** with balancing method
- In-line proof test by simulating partial proof-test with **fieldcheck**




Principle of the verification of an electromagnetic flowmeter with FieldCheck.

# Partial proof test with Fieldcheck (PTC $\approx$ 90 %)



Promass 80, 83






# Fieldcheck: In-Line Verification Promass, Promag, Prowirl


## Transformer...

- Zero point verification of outputs
- Verification of signal processing
- Linearity check of measuring amplifier
- Linearity check of output signals




...sensor verification suitable to measuring principle, e.g. Promass

- Stimulating coils
- Signal coils
- Temperatur sensors



## Example 5 - Temperature

iTEMP TMT 112/122/162/182



TMT 112



TMT 122



TMT 162



TMT 182



## iTEMP TMT 112/122/162/182

---

### Safety function:

- Temperature measurement (4...20 mA)
- Min, max, range
- SIL 2

### Proof test procedures:

Test criterion: trip level  $\pm 2\%$

- test with reference temperature measurement (PTC  $\approx 98\%$ )
- simulation with input resistor incl. short circuit/ interruption

### Test interval:

- $\leq 1$  year with 2/3-wire RTD or thermocouple („low stress“  $\leq 0,1$  g)
- $\leq 5$  years with 4-wire RTD („low stress“  $\leq 0,1$  g)

## Environmental Effect on Thermocouples/RTDs

### Effect on Thermocouples/RTDs

- Failure rates for separate elements with „high stress“  $> 0,1 \text{ g}$  **20x higher!**

Example:

<i>Thermocouple Failure Mode Distribution (close coupled)</i>	<b>Low Stress Fit</b>	<b>Percentage</b>	<b>High Stress</b>	<b>Percentage</b>
Open Circuit (Burn-out)	95	95%	1900	95%
Short Circuit (Temperature measurement in error)	4	4%	80	4%
Drift (Temperature measurement in error)	1	1%	20	1%
	<i>total</i>	<i>total</i>	<i>total</i>	<i>total</i>
	100	100%	2000	100%

## Overview Proof-tests E+H Instruments

Device	Type	Electronic	SIL	Safety function	Proof test procedure	Proof test interval	Proof test coverage	Tolerance
Liquiphant M/S	FTL 5x FTL 7x	FEL51,52, 54,55,56,58	2	min/max	Wet test Test-button <sup>1)</sup>	≤ 5 years On request	98 % --	--
Liquiphant M/S	FTL 5x FTL 7x	FEL57 (PFM)	2 (3)	min/max max	Wet test Test-button <sup>2)</sup>	≤ 5 years <sup>3)</sup> ≤ 1 year	98 % 90 %	--
Liquiphant FS	FTL 8x		3	min/max	Wet test Test-button <sup>1)</sup>	≤ 12 years On request	98 %	--
Levelflex	FMP 5x		2 (3)	min/max/ range Interface	Wet test Test simulation	≤ 3 years ≤ 1 year	98 % 92 %	± 2 %
Micropilot	FMR 5x		2 (3)	min/max/ range	Wet test Test simulation	≤ 2 years ≤ 1 year	98 % 55 %	± 2 %
Cerabar S Deltabar S	PMC PMP		2 (3)	min/max/ range	Wet test Test simulation	≤ 5 years	98 % 50 %	± 2 %

<sup>1)</sup> test only subsequent safety loop

<sup>2)</sup> complete test simulation

<sup>3)</sup> only low density media (<0,7)

## Overview Proof-tests E+H Instruments

Device	Type	Electronic	SIL	Safety function	Proof test procedure	Proof test interval	Proof test coverage	Tolerance
Promass	80,83		2 (3)	volume mass/density Min/max/ range	Calibration Totalizer Field check	$\leq 5$ years $\leq 5$ years $\leq 1$ year	98 % 98 % 90 %	Reference accuracy
Promass 200	E200 F200		2 (3)	volume mass/density Min/max/ range	Calibration Totalizer	$\leq 5$ years $\leq 5$ years $\leq 1$ year	98 % 98 % 90 %	Reference accuracy
Promag Prowirl	50/53 72/73		2	Min/max/ range	Calibration Fieldcheck	$\leq 5$ years $\leq 1$ year	98 % 90 %	Reference accuracy
Temperatur iTemp	TMT 1x2		2	min./max/ range	Calibration with reference resistor	$\leq 1$ year <sup>4)</sup> $\leq 5$ years <sup>5)</sup>	98 %	$\pm 2$ %

<sup>4)</sup> 2/3 wire RTD or thermocouple (low stress environment  $\leq 0,1$  g)

<sup>5)</sup> 4 wire RTD (low stress environment  $\leq 0,1$  g)

# Proof-Test Documentation W@M Lifecycle Management





- 





# Functional Proof Testing of SIS

## People for Process Automation

Herzlich Willkommen, Max Muster

[Start](#) | [Planung](#) | [Beschaffung](#) | [Installation, Inbetriebnahme, Betrieb](#)
[Installed Base Assistant](#) | [Produktstatus](#) | [Ersatzteilsuche](#) | [Download Area](#) | [Statusbericht](#)
[Installation, Inbetriebnahme, Betrieb](#) > [Installed Base Assistant](#)
[Navigation](#) | [Analyse](#)
Ansicht: [Standort](#)

- MUSTER AG
  - A - Aufbereitung
  - B - Produktion
    - Abwasserbehandl.
    - Produktion A
      - B 227
      - FIC 220**
      - Leimschmelz
      - LIC 221 -
      - LIC 225
      - LT 101
      - PIC 225
      - QIC 222
      - QIT 002
      - Reserve\_Dr
      - TC 224
      - TC 226
      - TC 227
    - Produktion B
  - C - Logistik
  - D - Unterhalt
  - E - Pumpwerk
  - Rohstoffsilo 1 (Freig)
  - Rohstoffsilo 2 (Freig)
  - Tank 1 - NaOH
  - Tank 2 - HCL
  - Tank 3 - H2SO4
  - Tank 4 - HCL
  - Y - Entsorgung

**TAG / KKS** FIC 220  
**Bestellcode** 53H65-A00B1AA0AAA  
**Gerätetyp** Magnetisch-Induktive Durchflussmessung  
**Hersteller** Endress+Hauser  
**Offene Aktivitäten (2)**

**MUSTER AG**
 9403 Goldach  
 Schweiz

[Übersicht](#) | [Details](#) | [Anhänge \(9\)](#) | [Ersatzteile](#) | [Logbuch](#) | [Weitere Produktinformationen](#)


**TAG / KKS** FIC 220  
**Seriennummer** 620E4419000  
**Bestellcode** 53H65-A00B1AA0AAA  
**Kurzname** Promag 53H  
**Gerätetyp** Magnetisch-Induktive Durchflu  
**Hersteller** Endress+Hauser  
**Herstellungsdatum** 2004  
**Software Version**  
**Anmerkungen**  
**Messbereich**  
**Messaufgabe**



**Umgebungsbedingungen** ☒ Normal  
**Kritikalität** ☒ Hoch  
**Instandsetzungsrisiko** ☒ Gering

**Standortinformationen****Produktstatus** ☒ Verfügbar

# People for Functional Proof Testing of Smart Process Automation

Endress+Hauser

Hilfe

Herzlich Willkommen, Max Muster

[Start](#) [Planung](#) [Beschaffung](#) [Installation, Inbetriebnahme, Betrieb](#)
[Installed Base Assistant](#) [Produktstatus](#) [Ersatzteilsuche](#) [Download Area](#) [Statusbericht](#)  
 Installation, Inbetriebnahme, Betrieb > [Installed Base Assistant](#)
[Navigation](#) [Analyse](#)

Ansicht: Standort



- MUSTER AG
  - A - Aufbereitung
  - B - Produktion
    - Abwasserbehandlungsanlage
    - Produktion A
      - B 227
      - FIC 220
      - Leimschmelze
      - LIC 221 -
      - LIC 225
      - LT 101
      - PIC 225
      - QIC 222
      - QIT 002
      - Reserve\_Dr...
      - TC 224
      - TC 226
      - TC 227
    - Produktion B
  - C - Logistik
  - D - Unterhalt
  - E - Pumpwerk
  - Rohstoffsilo 1 (Freig)
  - Rohstoffsilo 2 (Freig)
  - Tank 1 - NaOH
  - Tank 2 - HCL
  - Tank 3 - H2SO4
  - Tank 4 - HCL
  - Y - Entsorgung
  - Zentrallager
  - neu geliefert

**TAG / KKS** FIC 220  
**Bestellcode** 53H65-A00B1AA0AAAJ  
**Gerätetyp** Magnetisch-Induktive Durchflussmessung  
**Hersteller** Endress+Hauser

Offene Aktivitäten (2)

**MUSTER AG**9403 Goldach  
Schweiz
[Übersicht](#) [Details](#) [Anhänge \(9\)](#) [Ersatzteile](#) [Logbuch](#) [Weitere Produktinformationen](#)
**Ereignisliste**

Datum	Kategorie	
11.03.04	Produktion	
11.08.09	Betrieb	
03.11.09	Kalibrierung	
17.12.09	Kalibrierung	
04.01.10	Betrieb	
12.02.10	Kalibrierung	
25.02.10	Reparatur	
22.03.10	Kalibrierung	
22.03.10	Kalibrierung	
22.03.10	Kalibrierung	
22.06.10	Kalibrierung	
22.06.10	Kalibrierung	
22.06.10	Konfiguration	
12.11.10	Kalibrierung	
01.02.12	Wartung	

15 von 15

**Kategorie** Wartung  
**Short Description** Wartung  
**Description** Bitte gerät jährlich warten...  
**Due date** 30.09.10  
**Responsible** Max Muster  
**History**  
 1.2.2012 Max Muster State changed from:'in\_work' to:'done'  
 20.9.2010 Max Muster State changed from:'planned' to:'in\_work'

# Functional Proof Testing of SIS

## People for Process Automation

Herzlich Willkommen, Max Muster

[Start](#) | [Planung](#) | [Beschaffung](#) | [Installation, Inbetriebnahme, Betrieb](#)
[Installed Base Assistant](#) | [Produktstatus](#) | [Ersatzteilsuche](#) | [Download Area](#) | [Statusbericht](#)
[Installation, Inbetriebnahme, Betrieb](#) > [Installed Base Assistant](#)
[Navigation](#) | [Analyse](#)
Ansicht: [Standort](#)

- MUSTER AG
  - A - Aufbereitung
  - B - Produktion
    - Abwasserbehandl.
    - Produktion A
      - B 227
      - FIC 220**
      - Leimschmelz
      - LIC 221 -
      - LIC 225
      - LT 101
      - PIC 225
      - QIC 222
      - QIT 002
      - Reserve\_Dr
      - TC 224
      - TC 226
      - TC 227
    - Produktion B
  - C - Logistik
  - D - Unterhalt
  - E - Pumpwerk
  - Rohstoffsilo 1 (Freig)
  - Rohstoffsilo 2 (Freig)
  - Tank 1 - NaOH
  - Tank 2 - HCL
  - Tank 3 - H2SO4
  - Tank 4 - HCL
  - Y - Entsorgung

**TAG / KKS** FIC 220  
**Bestellcode** 53H65-A00B1AA0AAAJ  
**Gerätetyp** Magnetisch-Induktive Durchflussmessung  
**Hersteller** Endress+Hauser  
**Offene Aktivitäten (2)**

**MUSTER AG**
 9403 Goldach  
 Schweiz

[Übersicht](#) | [Details](#) | [Anhänge \(9\)](#) | [Ersatzteile](#) | [Logbuch](#) | [Weitere Produktinformationen](#)


**TAG / KKS** FIC 220  
**Seriennummer** 620E4419000  
**Bestellcode** 53H65-A00B1AA0AAAJ  
**Kurzname** Promag 53H  
**Gerätetyp** Magnetisch-Induktive Durchflu  
**Hersteller** Endress+Hauser  
**Herstellungsdatum** 2004  
**Software Version**  
**Anmerkungen**  
**Messbereich**  
**Messaufgabe**



**Umgebungsbedingungen** ☒ Normal  
**Kritikalität** ☒ Hoch  
**Instandsetzungsrisiko** ☒ Gering

**Standortinformationen****Produktstatus** ☒ Verfügbar



Herzlich Willkommen, Max Muster

[Hilfe](#) | [Profil](#) | [Abmelden](#)[Start](#) | [Planung](#) | [Beschaffung](#) | [Installation, Inbetriebnahme, Betrieb](#)[Installed Base Assistant](#) | [Produktstatus](#) | [Ersatzteilsuche](#) | [Download Area](#) | [Statusbericht](#)[Installation, Inbetriebnahme, Betrieb](#) > [Installed Base Assistant](#)[Navigation](#) | [Analyse](#)Ansicht: [Standort](#)

- MUSTER AG
  - A - Aufbereitung
  - B - Produktion
    - Abwasserbehandl.
    - Produktion A
      - B 227
      - FIC 220
      - Leimschmelz
      - LIC 221 -
      - LIC 225
      - LT 101
      - PIC 225
      - QIC 222
      - QIT 002
      - Reserve\_Dr
      - TC 224
      - TC 226
      - TC 227
    - Produktion B
  - C - Logistik
  - D - Unterhalt
  - E - Pumpwerk
  - Rohstoffsilo 1 (Freig)
  - Rohstoffsilo 2 (Freig)
  - Tank 1 - NaOH
  - Tank 2 - HCL
  - Tank 3 - H2SO4
  - Tank 4 - HCL
  - Y - Entsorgung
  - Zentrallager
  - neu geliefert

**TAG / KKS** FIC 220  
**Bestellcode** 53H65-A00B1AA0AAAJ  
**Gerätetyp** Magnetisch-Induktive Durchflussmessung  
**Hersteller** Endress+Hauser  
**Offene Aktivitäten (2)**

**MUSTER AG**9403 Goldach  
Schweiz[Übersicht](#) | [Details](#) | [Anhänge \(9\)](#) | [Ersatzteile](#) | [Logbuch](#) | [Weitere Produktinformationen](#)Kategorie  Herkunft 

Name	Kategorie	Typ	Version	Sprache
<a href="#">FieldCareConfiguration_100622_Promag / 53 / V1.02.0x.pdf</a>				
<a href="#">EW Durchflusskalibrierung</a>	Kalibrierprotokoll	Dokument	2004.02.26	Deutsch
<a href="#">EW Promag 53 PROFIBUS-DP/PA BeschreibungGerätefunktionen</a>	Betriebsanleitung	Dokument	2001.04.01	Deutsch
<a href="#">EW Promag 53 PROFIBUS-DP/PA Betriebsanleitung</a>	Betriebsanleitung	Dokument	2003.10.15	Deutsch
<a href="#">EW PROline Promag 53 PROFIBUS-DP/PA ATEX II 2G Ex documentation</a>	Sicherheit	Dokument	2003.12.15	Deutsch
<a href="#">EW PROline Promag 53 PROFIBUS-DP/PA ATEX II 3G Ex documentation</a>	Sicherheit	Dokument	2001.11.01	Deutsch
<a href="#">EW Proline Promag H Sonderdokumentation Specialdocumentation Documentation special</a>	Sicherheit	Dokument	2003.12.01	Deutsch
<a href="#">EW PROMAG 50/53 H Technische I</a>	Technische Information	Dokument	2004.02.01	Deutsch
<a href="#">EW Field Service Report</a>	Service Bericht	Dokument	2010.01.05	Deutsch

1 von 9

**Details**

Weitere Dokumente finden Sie unter 'Weitere Produktinformationen'

# Proof-Test protocol: Example Micropilot S

<b>System-specific data</b>		
Company	Mustermann AG	
Measuring points / TAG no.		
System		
Device type / Order code		
Serial number of device		
Name		
Date		
Signature		
<b>Device-specific commissioning parameters</b>		
Empty calibration		
Full calibration		
Proof-test protocol		
Test stage	Set point	Actual value
1. Current value 1		
2. Current value 2		
3. If necessary current value 3		
4. If necessary current value 4		
5. If necessary current value 5		



## Endress+Hauser Service

- Periodic Proof-tests
- Calibration Service



# Endress+Hauser Verification and Proof-Test Service

---

- Periodic **verification** with Fieldcheck
  - Promass
  - Promag
  - Prowirl
- Proof-Test via **Calibration Service**
- Electronic **data recording** and **Documentation**



## Order Code Structures for SIL devices

---

### 3 Options:

1. Older devices assessed by **proven-in-use experience**  
(e.g. Levelflex FMP 4x, Promass 80)
  - order standard device 4...20 mA
  - order safety manual separately or
  - download safety manual from [www.endress.com/SIL](http://www.endress.com/SIL)
2. Cerabar, Deltabar
  - order standard device with SIL –Declaration of conformity (back-pack)
  - device is delivered with safety manual, SIL Declaration of Conformity with serial No. of product, SIL marking
3. New products **developed acc. to IEC 61508**  
(e.g. Levelflex FMP 5x, Promass 200)
  - order SIL device (separate order code)
  - device is delivered with safety manual, declaration of conformity/Certificate, SIL marking





- manufacturer declaration
- fundamental safety parameters
- assessment report
- application information
- parameter settings

- Engine



**SIL-Konformitätserklärung**

Funktionale Sicherheit nach IEC 61508

Gerät/Device	Micropilot FMR50/51/52/53/54/56/57
Handbuch zur Funktionalen Sicherheit/ Functional safety manual	SD001087F/00
Sicherheitsfunktion/Safety function	MIN, MAX, Bereich/Range
SIL	2, 3 <sup>★3</sup>
HFT	0
Gerätetyp/Device type	B
Betriebsart/Mode of operation	Low demand mode, High demand mode
SFF	92 %
$PFD_{avg}^{★1} \quad T_1 = 1 \text{ Jahr/year}$ (einkanalig/single channel)	$1.09 \times 10^{-3}$
$PFD_{avg}^{★1} \quad T_1 = 2 \text{ Jahre/years}$ (einkanalig/single channel)	$2.17 \times 10^{-3}$
PFH	$2.45 \times 10^{-7} \text{ 1/h}$
$\lambda_{sd}^{★2}$	15 FIT
$\lambda_{su}^{★2}$	520 FIT
$\lambda_{ed}^{★2}$	2438 FIT
$\lambda_{eu}^{★2}$	245 FIT
$\lambda_{bez}^{★2}$	3218 FIT
MTBF <sup>★4</sup>	50 Jahre/years

# Safety Manual at “www.endress.com/SIL”

•Homepage •PRODUKTE •Produktprogramm •Füllstand •Kontinuierlich / flüssig  
Radar Geführtes Radar Ultraschall Kapazitiv Hydrostatisch Differenzdruck Radiometrisch Spezifikationsblatt

**Füllstand**  
■ Zusätzliche Informationen  
■ FMP 40  
■ FMP 41 C

**Levellflex M FMP 40**

Smart Transmitter für kontinuierliche Füllstandmessung in Schüttgütern und Flüssigkeiten. Preiswerte 4...20 mA-Zweidrahttechnik. Geeignet für den Einsatz im Ex-Bereich.

**Einsatzbereich**  
Der Levelflex M dient der kontinuierlichen Füllstandmessung von pulverförmigen bis körnigen Schüttgütern z.B. Kunststoffgranulat und Flüssigkeiten. Alle Sonden mit Prozessanschlüssen ab ¾" und Flansche ab DN40 / 1 ½" verfügbar.

- Seilsonden, vor allem zur Messung in Schüttgütern, Messbereich bis 35 m

Suche  
Seitenübersicht  
Kontakt  
AGB/Disclaimer  
**Download**  
**My Focus**

Weitere Info:  
**Download (FMP40)**  
**Zertifikate (FMP40)**

•Homepage •PRODUKTE •Produktprogramm •Füllstand •Kontinuierlich / flüssig  
Radar Geführtes Radar Ultraschall Kapazitiv Hydrostatisch Differenzdruck Radiometrisch Spezifikationsblatt

**Füllstand**  
■ Zusätzliche Informationen  
■ FMP 40  
■ FMP 41 C

**Approvals & Certificates** **Results**

**Levellflex M (FMP40)**

There are several Approval Types found concerning to the given product.  
Would you please select an Approval Type, to display them.

Approval Type: Please select

- EC-Declaration
- North America
- FM...
- CSA...
- Others
- MARINE ...
- East Europe...
- ASIA...
- Fieldbus conforma...
- SIL...
- Australia...

## Safety Manual

Differenzdruck-Transmitter  
**deltabar S FMD 230/235**  
**deltabar S FMD 230/235**  
mit 4...20 mA Ausgangssignal

Handbuch zur Funktions- und Sicherheit

**Endress + Hauser**  
The Power of Smart Process

# The Functional Safety Manual

## Contents

- Set-up of the safety system
- Description of the safety function
- Safety Parameters
- Ambient conditions, tolerance, restrictions
- Behaviour under normal and fault operation
- Installation and commissioning
- Parametrisation
- Functional proof test
- Maintenance and repair

Functional Safety Manual

**Levelflex**  
**FMP50/51/52/53/54/55/56/57**  
Guided Level-Radar for Liquids and Bulk Solids  
with 4 to 20 mA Output Signal


**Application**  
Operating minimum (e.g. dry run protection), maximum (e.g. overflow protection) and range monitoring of liquids and bulk solids of all types in systems to satisfy particular safety systems requirements as per IEC 61508 Edition 2.0.

The measuring device fulfils the requirements concerning:

- Functional safety as per IEC 61508 Edition 2.0
- Explosion protection (depending on the version)
- Electromagnetic compatibility as per EN 61326 and NAMUR recommendation NE 21
- Electrical safety as per IEC/EN 61010-1


**Your benefits**

- Used for level monitoring (MIN, MAX, range) up to SIL 2 (single-channel architecture) or SIL 3 (multi-channel architecture, also with homogeneous redundancy)
- Independently assessed and certified by TÜV Rheinland as per IEC 61508 Edition 2.0
- Permanent self-monitoring
- Continuous measurement
- Measurement is virtually independent of product properties
- Measurement is possible even at strongly agitated surfaces and foam
- Easy commissioning
- Also suitable for interface measurement
- Proof-test possible without dismantling of the device and without variation of the level


Endress+Hauser   
People for Process Automation

# The Functional Safety Manual- contents

## Set-up of the safety system




## Safety related output signal:



Kenngröße gemäß IEC 61508		Wert
Sicherheitsfunktionen	MIN-Sicherheit	MAX-Sicherheit
SIL (Hardware)	2 (einkanalig), 3 (mit SIL 3-fähiger Auswahlhaltung), → 18, "Anhang"	
SIL (Software)	3	
HFT	0	
Gerätetyp	B	
Betriebsart	Low demand mode	
SFF	92 %	94 %
MTTR	8 h	
Empfohlenes Zeitintervall für Wiederholungsprüfung $T_1$	1 Jahr	
$\lambda_{sd}$	2 FIT	1 FIT
$\lambda_{su}$	334 FIT	341 FIT
$\lambda_{dd}$	187 FIT	188 FIT
$\lambda_{du}$	43 FIT	34 FIT
$\lambda_{tot}^{*1}$	566 FIT	1000 FIT
Slide 80	Ken Wong Mik	
$PF_{avg}$ für $T_1 = 1 \text{ Jahr}^{*2}$	$1,85 \times 10^{-4}$	$1,46 \times 10^{-4}$

## Proof test interval

1001D





# Safety by Choice, not by Chance!

**Micropilot**



**Levelflex**



Product	Type	Assessment	Rating
Cerabar S	PMC71, PMP71,72,75	EN 61508	SIL 2/3
Cerabar M	PMC 5x	prior use	SIL 2
Deltabar S	PMD 75, 76,77, 78	EN 61508	SIL 2/3
Deltapilot S	FMB 70	EN61508	SIL 2/3
Liquiphant M/S FTL 5x, 7x FEL 5x		EN 61508	SIL 2
Liquiphant M/S FTL 5x 7x, FEL 57 (PFM)		EN 61508	SIL 2/3
Liquiphant FS	FTL 8x	EN 61508	SIL 3
Liquicap M	FMI 50, 51	EN 61508	SIL 2
Levelflex M	FMP 40, 41C, 45	prior use	SIL 2
Levelflex M	FMP 5x	IEC 61508	SIL 2/3
Micropilot M	FMR 230, 231, 240, 244, 245	prior use	SIL 2
Micropilot	FMR 5x	EN 61508	SIL 2/3
Gammapilot M	FMG 60 (limit switch)	EN 61508	SIL 2/3
Promass	80, 83	prior use	SIL 2
Promag	50, 53	prior use	SIL 2
Prowirl	72, 73	prior use	SIL 2
Liquiline	CM 42	IEC 61508	SIL 2
iTEMP	TMT 112, 122, 182, 162	prior use	SIL 2
Transmitter	RMA 422, RMA 42	prior use	SIL 2

**Liquiphant FS**



**Cerabar S Deltabar S**



**Promag**

**RMA 42**



**Promass 80/83**

# Thank you very much and much success! Good Bye!

